




# CERTIFICATE

<b>Certificate of NS protection</b>		Nr.: 21-241-01
<b>Manufacturer / Applicant</b>	<b>ComAp a.s.</b> U Uranie 1612/14a; 170 00 Praha 7 Czech Republic	
<b>Type of NS protection</b>	InteliSys Gas, AIO-GAS, InteliSys GSC-C, InteliGen GSC-C, InteliGen GSC	
<b>Central NS protection</b>	<input checked="" type="checkbox"/>	
<b>Integrated NS protection</b>	<input type="checkbox"/>	
<b>Network connection rule</b>	<b>SOP-9-1_14 GCC Certification Program, 11/20</b>  <u>Based on:</u>  <b>VDE-AR-N 4105:2018-11 Generators connected to the low-voltage distribution network</b> – Technical minimum requirements for connection and parallel operation of power generation systems connected to the low-voltage network	
<b>Test requirement</b>	<b>DIN VDE V 0124-100 (VDE V 0124-100):(2020-06)</b>  “Network integration of power generation systems – Low voltage” Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network	
<b>Test Report</b>	<b>21PP125-01_0 dated 2021-07-28</b>	
The network and system protection designated above meets the requirements of VDE-AR-N 4105:2018-11.		

Kaufbeuren, 2021-09-08

**Kiwa Primara GmbH**  
 Gewerbestraße 28  
 87600 Kaufbeuren  
 Germany  
 Tel. +49 8341 99726-0  
 info@primara.net  
 www.kiwa.de

**Raphael Rader**  
 Certification Engineer



This NS protection certificate shall not be used in extracts






## Annex 1 Description of the system

The EZE controllers IntelliSys Gas, AIO-GAS, IntelliSys GSC-C, IntelliGen GSC-C, IntelliGen GSC are controllers for genset applications manufactured by ComAp, a.s., which combine the following functions in one hardware:

- Engine operation/control (start, stop operation)
- Engine protection (oil pressure, water temperature, cylinder temperatures, etc.)
- Generator control (voltage control, active and reactive power control, cos φ control)
- Generator protection (overvoltage, undervoltage, overcurrent, short-circuit current, overload)
- Network voltage monitoring and generator shutdown if network values are outside adjusted limits (voltage and frequency monitoring)

Basically, the structure of the control systems can be divided into two levels. The upper level is responsible for active and reactive power management. Based on the selected mode, the required active and reactive power is made available for the lower level. At the lower level, the speed demand of the engine control unit (SRO) and the voltage demand (VRO) of the generator excitation unit are influenced.

A typical application of a control device is shown in the following figure.



For the certification, the NS protection and the PAV,E monitoring were considered.

The controller was tested with a "starter kit" simulation setup, in which the various feedback signals were implemented via switches and potentiometers in order to simulate realistic operation.



## Annex 2

## E.7 Extract of the test report for NS protection

No.: 21PP125-01\_0

„Determination of electrical properties“

## Test report NS protection

Type of NS protection	InteliSys Gas, AIO-GAS, InteliSys GSC-C, InteliGen GSC-C, InteliGen GSC	Further manufacturer information <i>Valid parameter set:</i> "SPtM under50kW.ant" or "SPtM over50kW.ant"		
Software-Version:	Type	Software-Version	Version Grid-Code Module	
	InteliSys Gas	IS2GASXX-1.9.0	V1.2	
	AIO-GAS	AIO-GAS-1.7.0		
	InteliSys GSC-C	IS2GSC-1.3.0		
	InteliGen GSC-C	IG2GSC-1.3.0		
	InteliGen GSC	IG2GSC-1.3.0		
Manufacturer:	<b>ComAp a.s.</b> U Uranie 1612/14a; 170 00 Praque 7; Czech Republic			
Measurement period:	From 2021-04-22 to 2021-07-01			

Protective function	Sitrling generators, fuel cells			Inverter(s)		
	Synchronous and asynchronous generators with $P_n \leq 50\text{kW}$ coupled directly or via inverters			Directly coupled synchronous and asynchronous generators with $P_n > 50\text{kW}$		
	Set Value	Tripping Value	Tripping time NS Protection*	Set Value	Tripping Value	Tripping time NS Protection*
Rise-in-voltage protection $U_{>>}$	$1,15 * U_n$	$1,15 * U_n$	38ms	$1,25 * U_n$	$1,255 * U_n$	36ms
Rise-in-voltage protection $U_{>}$	$1,10 * U_n$	$1,10 * U_n$	10 min Mittelwert	$1,10 * U_n$	$1,10 * U_n$	10 min mean value
Voltage drop protection $U_{<}$	$0,8 * U_n$	$0,793 * U_n$	59ms	$0,8 * U_n$	$0,792 * U_n$	1,027s
Voltage drop protection $U_{<<}$	Not applicable			$0,45 * U_n$	$0,444 * U_n$	321ms
Frequency decrease protection $f_{<}$	47,5Hz	47,50Hz	77ms	47,5 Hz	47,50Hz	67ms
Frequency decrease protection $f_{>}$	51,5Hz	51,51Hz	68ms	51,5 Hz	51,51Hz	76ms

\* The tripping time includes the period from the limit value violation  $U_{lf}$  until the tripping signal to the interface switch.

When planning the power generation system, the response time of the interface switch shall be added to the maximum time value obtained as indicated above.

 For integrated NS protection

Assigned to power generation unit of type	
Type integrated interface switch	
Response time of interface switch for integrated NS protection	
Verification of the entire functional chain "integrated NS protection – interface switch" has resulted in successful disconnection	<input type="checkbox"/>